

1.01 WASH LIGHTING

A. General

1. The fixture shall be an Outdoor rated IP 65 LED fixture with DMX control. The fixture shall be the Spectra Par 100 by Altman Stage Lighting, Inc. or approved equal.
2. The fixture shall incorporate a state of the art microprocessor-controlled solid state LED light engine, and on-board power supply.
3. The fixture shall incorporate silent, convection cooling without employing the use of fans or filters.
4. The fixture shall utilize a high efficiency lenses to determine beam angle and shape.
5. IES Photometric files shall be available upon request from the manufacturer to model light output using the industry standard design software.
6. The fixture shall comply with USITT DMX-512 A and ANSI E1.20-2006 Remote Device Management over USITT DMX 512A Standard (RDM) for DMX controlled models.
7. The fixture shall be ETL Listed to UL1573, and UL8750 LED for stage and studio use as well as Portable Electric Luminaires (UL Standard 153), Surface Mount Luminaires (UL Standard 1598) and IP 65 Rated for outdoor wet location use.
8. Fixtures which do not comply with this specification shall not be accepted.

B. Physical

1. The fixture shall be constructed of an Aluminum Die cast shell. Construction shall employ all corrosion-resistant materials and hardware and shall be free of pits and burrs.
 - a. Standard Finish shall be Epoxy Sandtex black, electrostatic application. The fixture shall be available with optional white, black, and custom color finishes as specified.
 - b. Power supply, cooling and electronics shall be integral to each unit.

- c. The housing shall serve as a heat sink to provide for convection cooling of the LED array, integral driver, and integral power supply.
 2. Fixture dimensions shall be 11.75" (300mm) L x 15.25" (390mm) H x 8" (203.2mm) Dia. and weigh 22lbs (9.9 kg).
 3. The fixture shall incorporate blending optics to reduce the projection of multiple shadows from the different color sources in the fixture.
 4. Each unit shall be provided with a low friction lens holder fully rotational via three insulated finger tabs.
 5. Fixture shall be equipped with three replaceable two-slot accessory holder with tool-free quick release lens holder clips with self-closing and self-locking accessory retaining latch.
 6. An integrated rigid flat steel yoke with locking dog tilt handle shall be available for overhead pipe mounting.
 - a. Pipe mounted fixtures shall be supplied with a cast iron C-clamp Altman #510 suitable for use on up to 2" (50mm) O.D. pipe. Clamp must incorporate a 360-degree rotational "safety stud" with locking bolt. Any clamp not offering this safety feature will not be acceptable.
 - b. Fixtures shall be supplied with safety cable for use when securing the fixture to a pipe.
 7. Power supply, cooling and electronics shall be integral to each unit.
- C. Thermal
 1. The luminaire shall be cooled via natural convection with no aide of fans or other cooling systems. The LED substrate is coupled to a highly efficient heat sink and cooling system for prolonged life of the LEDs. LED fixture housing shall transfer heat from the LED board and associated electronics to the outside environment.
 2. Under normal operating conditions, the LED engine shall be capable of 50,000 hours rated lifespan to LM-70 / 70% maximum calibrated intensity with convective cooling, units utilizing active cooling shall not be accepted.
 3. Ambient operating temperature shall be 32°F to 104°F (0 – 40 °C) and IP-65 rated for outdoor wet location use.

D. Electrical

1. The fixture shall be equipped with 100V to 240V 50/60 Hz auto-ranging internal power supply and requires power from a constant “non-dim” power source, and may be hard wired to the power source for permanent installation.
2. The fixture shall receive power, for portable use, via an inline hardwired 6’-0” (1.8m) power cord with:
 - a. 2 P&G (Stage Pin)
 - b. NEMA 5-15P
 - c. NEMA L520 (Twistlok)
 - d. Territory Power Plug

E. Control and User Interface

1. A local control keypad with an IP65 rated overlay with a three digit LCD display shall be provided for configuration and control of:
 - a. DMX-512A Device Address
 - b. Fixture Personality
 - c. Stand Alone (Manual) Operation
2. It shall be possible to lock out the control keypad at the fixture to prevent accidental change in fixture configuration during operation. Locking and unlocking the control keypad shall be via predefined key sequence.
3. Each fixture shall be compatible with the USITT DMX512-A control protocol and ANSI E1.20-2006 Remote Device Management over DMX512-A (RDM) standard. DMX and RDM Control shall be connected via integral 6’ control leads with installed 5-Pin XLR input and output connectors
4. The DMX-512A device address for each fixture shall be user selectable.
5. It shall be possible to set the DMX-512A device address for the fixture while the fixture is installed and connected to the system via the RDM (ANSI E1.20-2006 protocol) and an appropriate device such as a PC or a handheld programmer.
6. Fixtures which do not allow for setting of the DMX address via both local controls at the fixture and remotely while installed via RDM shall not be accepted.
7. The fixture shall have an available “Master Channel” function to provide control of intensity without changing the color of the output of the fixture. The Master

shall operate in either 8-bit or 16-bit resolution as defined by the configuration of the fixture.

8. The fixture shall have user selected personalities to correctly match response to the application and control system utilized. Personalities shall provide the following options which may be combined as desired:
 - a. 8 or 16 Bit DMX operation
 - b. Master Channel On / Off
 - c. Smoothing On / Off
 - d. Stand-alone effects
 - e. Stand-alone fixed output
9. The fixture shall be capable of standalone operation, activated and configured at the control keypad. Standalone modes shall include the following:
 - a. Fixed color temperature defined with local controls
 - b. Strobe with user selectable color and speed
 - c. Slave

F. Optical

1. Fixture shall feature a custom matrix of LEDs to provide color or tunable white light or fixed white light. Variations of LED matrices to include:
 - a. Red, Green, Blue, Amber
 - b. Red, Green, Blue, White
 - c. 3000, 6000 Kelvin white tune-able
 - d. Fixed white
 - e. Custom arrays.
2. All lenses to feature cosine beam and field distribution and feature a 4:1 beam to field distribution ratio.
3. Each unit shall include four tool free interchangeable lenses (VNSP, NSP, MFL, WFL). Lens changes shall be possible regardless of fixture orientation. Fixtures not offering this feature will not be acceptable.
4. Four (4) different Lens assemblies shall be available in variations of:
 - a. VNSP (Glass Very Narrow Spot)

- b. NSP (Glass Narrow Spot)
 - c. MFL (Glass Medium Flood)
 - d. WFL (Wide Flood)
- 5. The fixture shall incorporate blending optics to reduce the projection of multiple shadows from the different color sources in the fixture. The LED system shall be digitally driven using high-speed pulse width modulation (PWM).
 - 6. The fixture shall have an available “smoothing” mode which makes PWM control of LED levels imperceptible to video cameras and related broadcast equipment.
- G. Light Emitting Diodes
- 1. The fixture shall use a variety of LEDs for a wide range of color mixing or tuning for color models the standard configurations shall be Red, Green, Blue, and Amber LEDs or Red, Green, Blue and White LEDs. For white models the standard configurations shall be white LEDs at 3,000° Kelvin color temperatures or variable white between 3,000° and 6,000° Kelvin, with custom arrays available.
- H. Dimming Engine
- 1. Luminaire shall provide full range dimming performance based upon its DMX input control signal and configuration and shall be equipped with an LED system compatible with standard 8-bit and 16-bit input, with high resolution dimming.
 - 2. Dimming curves shall be optimized for smooth dimming at low intensities and over longer timed fades.
 - 3. LEDs shall be driven by Pulse Width Modulation. (PWM)
 - 4. Additional smoothing algorithms shall be available to augment the high resolution dimming engine.

END SPECIFICATION

©Altman Lighting 2017